

MUNICIPAL CORPORATION OF GREATER MUMBAI
MUMBAI FIRE BRIGADE

Fire safety requirements for LOFT

- 1) The loft shall be structurally sound and shall **not be** used for installing machinery, work place or human inhabitation. It should be used only for **STORAGE PURPOSE**.
- 2) The height of the loft shall not exceed 1.5 Meter and height of the floor below the loft shall not be less than 2.2 Meter.
- 3) The loft shall be constructed at least two meters away from the entrance of the premises.
- 4) The frontage of the loft shall not be covered, however handrail up to 3' height may be provided.
- 5) The stacking height on the loft shall be at least two feet below the ceiling.
- 6) Nothing shall be stored within the radius of one metre from any electric wiring or electric installation.
- 7) No any hazardous/inflammable material shall be stored.
- 8) One fire extinguisher of 9 kg capacity of Class ABC type having BIS certification mark shall be provided for 100 sq mtrs of the area at easily accessible place.

Sd/-
Chief Fire Officer
Mumbai Fire Brigade